



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)719-5649 Fax – (732)358-0168
Cert # 00407A Cert # 00430E
Asb # 01200

07/21/2025

Re: 520 Chestnut Ave, Trenton, NJ 08611

To whom it may concern,

We have sampled the drinking water at the above property for lead and copper. Please note the Federal Action for Copper is 1,300 ug/l (ppb) and for lead is 15 ug/l (ppb).

The following results were found to be above the action level for lead.

- 202 Sink 2nd Draw
- Kitchen Sink 2 1st Draw
- Closet Kitchen 1st Draw
- Teachers Room Basement 2nd Draw

Feel Free to contact us with any questions.

Ahron Susholz
(732)719-5649



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 1183102
Sampling Date : 07/15/2025
Date Received : 07/16/2025
Date Analyzed : 07/18/2025
Date Reported : 07/22/2025

Client Project : 520 CHESTNUT AVE TRENTON
Project Location : 520 CHESTNUT AVE TRENTON NJ

WSSN : NP

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
10611225	1-39	207 SINK 1ST DRAW	NA		0.0095	0.0020	Below
10611226	1-40	207 SINK 2ND DRAW	NA		<0.0020	0.0020	Below
10611227	1-41	STAFF SINK 1ST DRAW	NA		0.0043	0.0020	Below
10611228	1-42	STAFF SINK 2ND DRAW	NA		<0.0020	0.0020	Below
10611229	1-43	202 SINK 1ST DRAW	NA		0.0029	0.0020	Below
10611230	1-44	202 SINK 2ND DRAW	NA		0.0387	0.0020	Above
10611231	1-45	STAFF BATH 1ST FL 1ST DRAW	NA		0.0022	0.0020	Below
10611232	1-46	STAFF BATH 1ST FL 2ND DRAW	NA		<0.0020	0.0020	Below
10611233	1-47	102 SINK 1ST DRAW	NA		0.0046	0.0020	Below
10611234	1-48	102 SINK 2ND DRAW	NA		<0.0020	0.0020	Below
10611235	1-49	COSTODIAL SINK 1ST DRAW	NA		<0.0020	0.0020	Below
10611236	1-50	COSTODIAL SINK 2ND DRAW	NA		<0.0020	0.0020	Below
10611237	1-51	KIT SINK 1 1ST DRAW	NA		0.0045	0.0020	Below
10611238	1-52	KIT SINK 1 2ND DRAW	NA		<0.0020	0.0020	Below
10611239	1-53	KIT SINK 2 1ST DRAW	NA		0.0268	0.0020	Above

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A "<" indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 07/22/2025

AAT Project: 1183102

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
10611240	1-54	KIT SINK 2 2ND DRAW	NA		<0.0020	0.0020	Below
10611241	1-55	KIT SINK 3 1ST DRAW	NA		<0.0020	0.0020	Below
10611242	1-56	KIT SINK 3 2ND DRAW	NA		<0.0020	0.0020	Below
10611243	1-57	CLST KIT 1ST DRAW	NA		0.0268	0.0020	Above
10611244	1-58	TEACHERS RM BSMT 1ST DRAW	NA		<0.0020	0.0020	Below
10611245	1-59	TEACHERS RM BSMT 2ND DRAW	NA		0.0153	0.0020	Above
10611246	1-60	GIRLS BATH SINK 1 1ST DRAW	NA		<0.0020	0.0020	Below
10611247	1-61	GIRLS BATH SINK 1 2ND DRAW	NA		<0.0020	0.0020	Below
10611248	1-62	GIRLS BATH SINK 1 2ND DRAW	NA		<0.0020	0.0020	Below
10611249	1-63	GIRLS BATH SINK 2 1ST DRAW	NA		<0.0020	0.0020	Below
10611250	1-64	GIRLS BATH SINK 2 2ND DRAW	NA		<0.0020	0.0020	Below
10611251	1-65	BOYS BATH SINK 1 1ST DRAW	NA		0.0101	0.0020	Below
10611252	1-66	BOYS BATH SINK 1 2ND DRAW	NA		<0.0020	0.0020	Below
10611253	1-67	BOYS BATH SINK 2 1ST DRAW	NA		0.0029	0.0020	Below
10611254	1-68	BOYS BATH SINK 2 2ND DRAW	NA		<0.0020	0.0020	Below
10611255	1-69	BOYS BATH MAIN SINK 1 1ST DRAW	NA		<0.0020	0.0020	Below
10611256	1-70	BOYS BATH MAIN SINK 1 2ND DRAW	NA		<0.0020	0.0020	Below
10611257	1-71	BOYS BATH SINK 2 1ST DRAW	NA		0.0035	0.0020	Below
10611258	1-72	BOYS BATH SINK 2 2ND DRAW	NA		<0.0020	0.0020	Below
10611259	1-73	BOYS BATH SINK 3 1ST DRAW	NA		<0.0020	0.0020	Below
10611261	1-75	NURSE OFF SINK 1ST DRAW	NA		<0.0020	0.0020	Below
10611262	1-76	NURSE OFF SINK 2ND DRAW	NA		<0.0020	0.0020	Below
10611263	1-77	GIRLS BATH SINK 1 1ST DRAW	NA		0.0051	0.0020	Below

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A "<" indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
10611264	1-78	GIRLS BATH SINK 1 2ND DRAW	NA		<0.0020	0.0020	Below
10611265	1-79	GIRLS BATH SINK 2 1ST DRAW	NA		0.0062	0.0020	Below
10611266	1-80	GIRLS BATH SINK 2 2ND DRAW	NA		<0.0020	0.0020	Below
10611267	1-81	GIRLS BATH SINK 3 1ST DRAW	NA		0.0039	0.0020	Below
10611268	1-82	GIRLS BATH SINK 3 2ND DRAW	NA		<0.0020	0.0020	Below

Analyst Signature



Joseph Kenwabikise



Zachary St John

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 1183102
Sampling Date : 07/15/2025
Date Received : 07/16/2025
Date Analyzed : 07/18/2025
Date Reported : 07/22/2025

Client Project : 520 CHESTNUT AVE TRENTON NJ **Collected By :**
Project Location : 520 CHESTNUT AVE TRENTON NJ

WSSN : NP

Sample ID	Client Code	Sample Description	Purpose	Collection Tim	Results Copper mg/L (ppm)	Cu Threshold
10611225	1-39	207 SINK 1ST DRAW	NA		0.1669	Below
10611226	1-40	207 SINK 2ND DRAW	NA		0.1112	Below
10611227	1-41	STAFF SINK 1ST DRAW	NA		0.1322	Below
10611228	1-42	STAFF SINK 2ND DRAW	NA		0.0721	Below
10611229	1-43	202 SINK 1ST DRAW	NA		0.1500	Below
10611230	1-44	202 SINK 2ND DRAW	NA		0.7816	Below
10611231	1-45	STAFF BATH 1ST FL 1ST DRAW	NA		0.1741	Below
10611232	1-46	STAFF BATH 1ST FL 2ND DRAW	NA		0.0797	Below
10611233	1-47	102 SINK 1ST DRAW	NA		0.1231	Below
10611234	1-48	102 SINK 2ND DRAW	NA		0.0922	Below
10611235	1-49	COSTODIAL SINK 1ST DRAW	NA		0.0856	Below
10611236	1-50	COSTODIAL SINK 2ND DRAW	NA		0.1035	Below
10611237	1-51	KIT SINK 1 1ST DRAW	NA		0.0762	Below
10611238	1-52	KIT SINK 1 2ND DRAW	NA		0.0984	Below
10611239	1-53	KIT SINK 2 1ST DRAW	NA		0.2254	Below
10611240	1-54	KIT SINK 2 2ND DRAW	NA		0.0904	Below
10611241	1-55	KIT SINK 3 1ST DRAW	NA		0.0812	Below
10611242	1-56	KIT SINK 3 2ND DRAW	NA		0.1031	Below
10611243	1-57	CLST KIT 1ST DRAW	NA		0.5240	Below
10611244	1-58	TEACHERS RM BSMT 1ST DRAW	NA		0.1067	Below

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit. The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A "<" indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAP guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 07/22/2025

AAT Project: 1183102

Sample ID	Client Code	Sample Description	Purpose	Collection Tim	Results Copper mg/L (ppm)	Cu Threshold
10611245	1-59	EACHERS RM BSMT 2ND DRA	NA		0.1332	Below
10611246	1-60	GIRLS BATH SINK 1 1ST DRAW	NA		0.0772	Below
10611247	1-61	GIRLS BATH SINK 1 2ND DRAW	NA		0.2590	Below
10611248	1-62	GIRLS BATH SINK 1 2ND DRAW	NA		0.0208	Below
10611249	1-63	GIRLS BATH SINK 2 1ST DRAW	NA		0.0194	Below
10611250	1-64	GIRLS BATH SINK 2 2ND DRAW	NA		0.0123	Below
10611251	1-65	BOYS BATH SINK 1 1ST DRAW	NA		0.1271	Below
10611252	1-66	BOYS BATH SINK 1 2ND DRAW	NA		0.0841	Below
10611253	1-67	BOYS BATH SINK 2 1ST DRAW	NA		0.1250	Below
10611254	1-68	BOYS BATH SINK 2 2ND DRAW	NA		0.0846	Below
10611255	1-69	YS BATH MAIN SINK 1 1ST DR	NA		0.0638	Below
10611256	1-70	YS BATH MAIN SINK 1 2ND DR	NA		0.0591	Below
10611257	1-71	BOYS BATH SINK 2 1ST DRAW	NA		0.0845	Below
10611258	1-72	BOYS BATH SINK 2 2ND DRAW	NA		0.0718	Below
10611259	1-73	BOYS BATH SINK 3 1ST DRAW	NA		0.0772	Below
10611261	1-75	NURSE OFF SINK 1ST DRAW	NA		0.1387	Below
10611262	1-76	NURSE OFF SINK 2ND DRAW	NA		0.1024	Below
10611263	1-77	GIRLS BATH SINK 1 1ST DRAW	NA		0.0894	Below
10611264	1-78	GIRLS BATH SINK 1 2ND DRAW	NA		0.0712	Below
10611265	1-79	GIRLS BATH SINK 2 1ST DRAW	NA		0.0903	Below
10611266	1-80	GIRLS BATH SINK 2 2ND DRAW	NA		0.0707	Below
10611267	1-81	GIRLS BATH SINK 3 1ST DRAW	NA		0.0765	Below
10611268	1-82	GIRLS BATH SINK 3 2ND DRAW	NA		0.5496	Below

Analyst Signature



Joseph Kenwabikise



Zachary St John

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit. The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A "<" indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAP guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Attn : Joseph Perlstein

Email : joe@aaaleadpro.com

Phone : 732-668-9078

Project Location : 520 CHESTNUT AVE TRENTON NJ

AAT Project : 1183102

Client Project : 520 CHESTNUT AVE TRENTON

Date Reported 07/22/2025

Sample	Client Code	Analysis Requested	Completed	Analyst
10611225	1-39	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611226	1-40	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611227	1-41	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611228	1-42	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611229	1-43	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611230	1-44	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611231	1-45	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611232	1-46	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611233	1-47	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611234	1-48	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611235	1-49	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611236	1-50	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611237	1-51	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611238	1-52	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611239	1-53	Pb/Cu in Drinking Water	07/21/2025	Zachary St John
10611240	1-54	Pb/Cu in Drinking Water	07/21/2025	Zachary St John
10611241	1-55	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611242	1-56	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611243	1-57	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611244	1-58	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611245	1-59	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611246	1-60	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611247	1-61	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611248	1-62	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611249	1-63	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611250	1-64	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611251	1-65	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

NY State DOH ELAP -Lab ID #11864, Michigan State Lab # 9996

Date Printed: 07/22/2025 4:15AM

AAT Project: 1183102

Sample	Client Code	Analysis Requested	Completed	Analyst
10611252	1-66	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611253	1-67	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611254	1-68	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611255	1-69	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611256	1-70	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611257	1-71	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611258	1-72	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611259	1-73	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611261	1-75	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611262	1-76	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611263	1-77	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611264	1-78	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611265	1-79	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611266	1-80	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611267	1-81	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise
10611268	1-82	Pb/Cu in Drinking Water	07/21/2025	Joseph Kenwabikise

Reviewed By

Elyse Bidle
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.



AAA LEAD PROFESSIONALS
6 WHITE DOVE CT
LAKEWOOD NJ 08701
732-668-9078

SAME DAY	24 HR TAT	48 HR TAT	72 HR TAT

CHAIN OF CUSTODY

ADDRESS: 520 Chestnut Ave Trenton NJ

10 Cases

SAMPLE	ROOM	PLACE	AREA	
1-39	207	Sink	1 ST DRAW	
1-40	"	"	2 ND DRAW	
1-41	Staff	Sink	1 ST DRAW	
1-42	"	"	2 ND DRAW	
1-43	202	Sink	1 ST DRAW	
1-44	"	"	2 ND DRAW	
1-45	Staff bath	1st floor	1 ST DRAW	
1-46	"	"	2 ND DRAW	
1-47	102	Sink	1 ST DRAW	
1-48	"	"	2 ND DRAW	
1-49	Costodial	Sink	1 ST DRAW	
1-50	"	"	2 ND DRAW	
1-51	Kitchen	Sink 1	1 ST DRAW	
1-52	"	"	2 ND DRAW	
1-53	Kitchen	Sink 2	1 ST DRAW	
1-54	"	"	2 ND DRAW	
1-55	Kitchen	Sink 3	1 ST DRAW	
1-56	"	"	2 ND DRAW	
1-57	closet	Kitchen	1 ST DRAW	
1-58	"	"	2 ND DRAW	

TAKEN AND RELINQUISHED BY:

AHRON SUSHOLZ

Signature

DATE: 7 15 / 25 /

3192 11/17/17

Lexus Staffed
Accurate Analytical Testing

JUL 16 2025



AAA LEAD PROFESSIONALS
6 WHITE DOVE CT
LAKEWOOD NJ 08701
732-668-9078

SAME DAY	24 HR TAT	48 HR TAT	72 HR TAT

CHAIN OF CUSTODY

ADDRESS: 520 chestnut Ave. Trenton NJ

SAMPLE	ROOM	PLACE	AREA	
1-59	teachers room	basement	1 ST DRAW	
1-60	"	"	2 ND DRAW	
1-61	girls bath	Sink 1	1 ST DRAW	
1-62	"	"	2 ND DRAW	
1-63	girls bath	Sink 2	1 ST DRAW	
1-64	"	"	2 ND DRAW	
1-65	boys bath	Sink 1	1 ST DRAW	
1-66	"	"	2 ND DRAW	
1-67	boys bath	Sink 2	1 ST DRAW	
1-68	"	"	2 ND DRAW	
1-69	boys bath	main sink 1	1 ST DRAW	
1-70	"	"	2 ND DRAW	
1-71	boys bath	Sink 2	1 ST DRAW	
1-72	"	"	2 ND DRAW	
1-73	boys bath	Sink 3	1 ST DRAW	
1-74	"	"	2 ND DRAW	
1-75	nurse office	Sink	1 ST DRAW	
1-76	"	"	2 ND DRAW	
1-77	girls bath	Sink 1	1 ST DRAW	
1-78	"	"	2 ND DRAW	

TAKEN AND RELINQUISHED BY:

AHRON SUSHOLZ

Signature

DATE: 7 15 / 25 /



AAA LEAD PROFESSIONALS
6 WHITE DOVE CT
LAKEWOOD NJ 08701
732-668-9078

SAME DAY	24 HR TAT	48 HR TAT	72 HR TAT

CHAIN OF CUSTODY

ADDRESS: 520 chestnut Ave trenton nj

SAMPLE	ROOM	PLACE	AREA	
1-79	girls bath	sink 2	1 ST DRAW	
1-80			2 ND DRAW	
1-81	girls bath	sink 3	1 ST DRAW	
1-82			2 ND DRAW	
			1 ST DRAW	
			2 ND DRAW	
			1 ST DRAW	
			2 ND DRAW	
			1 ST DRAW	
			2 ND DRAW	
			1 ST DRAW	
			2 ND DRAW	
			1 ST DRAW	
			2 ND DRAW	
			1 ST DRAW	
			2 ND DRAW	
			1 ST DRAW	
			2 ND DRAW	

TAKEN AND RELINQUISHED BY:

AHRON SUSHOLZ

Signature

DATE: 7 15 / 25 /