



6 White Dove Ct. Lakewood NJ 08701  
Tel- (732)719-5649 Fax – (732)358-0168  
Cert # 00407A Cert # 00430E  
Asb # 01200

---

07/23/2025

Re: 544 Chestnut Ave, Trenton, NJ 08611

To whom it may concern,

We have sampled the drinking water at the above property for lead and copper. Please note the Federal Action for Copper is 1,300 ug/l (ppb) and for lead is 15 ug/l (ppb).

All results were found to be below the action level.

Feel Free to contact us with any questions.

Ahron Susholz  
(732)719-5649



30105 Beverly Road  
Romulus, MI 48174  
Ph: 734-629-8161; Fax: 734-629-8431

## Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

**Client :** AAA Lead Professionals  
6 White Dove Court  
Lakewood, NJ 08701

**Attn :** Joseph Perlstein      **Email :** joe@aaaleadpro.com  
**Phone :** 732-668-9078      **Fax :**

**AAT Project :** 1183101  
**Sampling Date :** 07/15/2025  
**Date Received :** 07/16/2025  
**Date Analyzed :** 07/17/2025  
**Date Reported :** 07/22/2025

**Client Project :** 544 CHESTNUT AVE TRENTON NJ      **Collected By :** AHRON SUSHOLZ

**WSSN :** NP

**Project Location :** 544 CHESTNUT AVE TRENTON NJ

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
10611201	1-15	PREP KIT SINK 1 1ST DRAW	NA		<0.0020	0.0020	Below
10611202	1-16	PREP KIT SINK 1 2ND DRAW	NA		0.0030	0.0020	Below
10611203	1-17	PREP KIT SINK 2 1ST DRAW	NA		0.0022	0.0020	Below
10611204	1-18	PREP KIT SINK 2 2ND DRAW	NA		<0.0020	0.0020	Below
10611205	1-19	PREP KIT SINK 3 1ST DRAW	NA		0.0098	0.0020	Below
10611206	1-20	PREP KIT SINK 3 2ND DRAW	NA		<0.0020	0.0020	Below
10611207	1-21	305 CLSS SINK 1ST DRAW	NA		<0.0020	0.0020	Below
10611208	1-22	305 CLSS SINK 2ND DRAW	NA		<0.0020	0.0020	Below
10611209	1-23	GIRLS BATH SINK 1ST DRAW	NA		<0.0020	0.0020	Below
10611210	1-24	GIRLS BATH SINK 2ND DRAW	NA		<0.0020	0.0020	Below
10611211	1-25	BOYS BATH SINK 1ST DRAW	NA		<0.0020	0.0020	Below
10611212	1-26	BOYS BATH SINK 2ND DRAW	NA		<0.0020	0.0020	Below
10611213	1-27	202 SINK 1ST DRAW	NA		<0.0020	0.0020	Below
10611214	1-28	202 SINK 2ND DRAW	NA		<0.0020	0.0020	Below
10611215	1-29	NURSE OFF SINK 1ST DRAW	NA		0.0044	0.0020	Below

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAP guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 07/22/2025

AAT Project: 1183101

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
10611216	1-30	NURSE OFF SINK 2ND DRAW	NA		<0.0020	0.0020	Below
10611217	1-31	BOYS BATH 2ND FL 1ST DRAW	NA		0.0022	0.0020	Below
10611218	1-32	BOYS BATH 2ND FL 2ND DRAW	NA		<0.0020	0.0020	Below
10611219	1-33	GIRLS BATH 2ND FL 1ST DRAW	NA		<0.0020	0.0020	Below
10611220	1-34	GIRLS BATH 2ND FL 2ND DRAW	NA		<0.0020	0.0020	Below
10611221	1-35	STAFF BATH GIRLS 1ST DRAW	NA		0.0021	0.0020	Below
10611222	1-36	STAFF BATH GIRLS 2ND DRAW	NA		<0.0020	0.0020	Below
10611223	1-37	MENS BATH STAFF 1ST DRAW	NA		<0.0020	0.0020	Below
10611224	1-38	MENS BATH 2ND DRAW	NA		<0.0020	0.0020	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road  
Romulus, MI 48174  
Ph: 734-629-8161; Fax: 734-629-8431

## Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

**Client :** AAA Lead Professionals  
6 White Dove Court  
Lakewood, NJ 08701

**Attn :** Joseph Perlstein **Email :** joe@aaaleadpro.com  
**Phone :** 732-668-9078 **Fax :**

**AAT Project :** 1183101

**Sampling Date :** 07/15/2025

**Date Received :** 07/16/2025

**Date Analyzed :** 07/17/2025

**Date Reported :** 07/22/2025

**Client Project :** 544 CHESTNUT AVE TRENTON NJ **Collected By :** AHRON SUSHOLZ

**WSSN :** NP

**Project Location :** 544 CHESTNUT AVE TRENTON NJ

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
10611201	1-15	PREP KIT SINK 1 1ST DRAW	NA		0.0509	Below
10611202	1-16	PREP KIT SINK 1 2ND DRAW	NA		0.1511	Below
10611203	1-17	PREP KIT SINK 2 1ST DRAW	NA		0.1383	Below
10611204	1-18	PREP KIT SINK 2 2ND DRAW	NA		0.1376	Below
10611205	1-19	PREP KIT SINK 3 1ST DRAW	NA		0.1057	Below
10611206	1-20	PREP KIT SINK 3 2ND DRAW	NA		0.1109	Below
10611207	1-21	305 CLSS SINK 1ST DRAW	NA		0.0031	Below
10611208	1-22	305 CLSS SINK 2ND DRAW	NA		<0.0025	Below
10611209	1-23	GIRLS BATH SINK 1ST DRAW	NA		<0.0025	Below
10611210	1-24	GIRLS BATH SINK 2ND DRAW	NA		<0.0025	Below
10611211	1-25	BOYS BATH SINK 1ST DRAW	NA		0.0339	Below
10611212	1-26	BOYS BATH SINK 2ND DRAW	NA		0.0091	Below
10611213	1-27	202 SINK 1ST DRAW	NA		0.1122	Below
10611214	1-28	202 SINK 2ND DRAW	NA		0.1037	Below
10611215	1-29	NURSE OFF SINK 1ST DRAW	NA		0.1379	Below
10611216	1-30	NURSE OFF SINK 2ND DRAW	NA		0.1383	Below
10611217	1-31	BOYS BATH 2ND FL 1ST DRAW	NA		0.0635	Below
10611218	1-32	BOYS BATH 2ND FL 2ND DRAW	NA		0.0690	Below
10611219	1-33	GIRLS BATH 2ND FL 1ST DRAW	NA		0.0420	Below
10611220	1-34	GIRLS BATH 2ND FL 2ND DRAW	NA		0.0348	Below

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAP guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 07/22/2025

AAT Project: 1183101

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
10611221	1-35	STAFF BATH GIRLS 1ST DRAW	NA		0.0505	Below
10611222	1-36	STAFF BATH GIRLS 2ND DRAW	NA		0.0310	Below
10611223	1-37	MENS BATH STAFF 1ST DRAW	NA		0.0150	Below
10611224	1-38	MENS BATH 2ND DRAW	NA		0.0157	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 µg/L for Pb and 1.3 µg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road  
Romulus, MI 48174  
Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals  
6 White Dove Court  
Lakewood, NJ 08701

Attn : Joseph Perlstein

Email : joe@aaaleadpro.com

Phone : 732-668-9078

AAT Project : 1183101

Client Project : 544 CHESTNUT AVE TRENTON

Date Reported : 07/22/2025

Project Location : 544 CHESTNUT AVE TRENTON NJ

Sample	Client Code	Analysis Requested	Completed	Analyst
10611201	1-15	Pb/Cu in Drinking Water	07/17/2025	Joseph Kenwabikise
10611202	1-16	Pb/Cu in Drinking Water	07/17/2025	Joseph Kenwabikise
10611203	1-17	Pb/Cu in Drinking Water	07/17/2025	Joseph Kenwabikise
10611204	1-18	Pb/Cu in Drinking Water	07/17/2025	Joseph Kenwabikise
10611205	1-19	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611206	1-20	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611207	1-21	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611208	1-22	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611209	1-23	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611210	1-24	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611211	1-25	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611212	1-26	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611213	1-27	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611214	1-28	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611215	1-29	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611216	1-30	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611217	1-31	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611218	1-32	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611219	1-33	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611220	1-34	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611221	1-35	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611222	1-36	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611223	1-37	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise
10611224	1-38	Pb/Cu in Drinking Water	07/18/2025	Joseph Kenwabikise

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

Elyse Bidle

Reviewed By

Elyse Bidle  
Quality Assurance Coordinator

---

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.



AAA LEAD PROFESSIONALS  
6 WHITE DOVE CT  
LAKEWOOD NJ 08701  
732-668-9078

SAME DAY	24 HR TAT	48 HR TAT	72 HR TAT

CHAIN OF CUSTODY

ADDRESS: 544 Chestnut Ave Larchmont NJ

W. C. C. C. C.

SAMPLE	ROOM	PLACE	AREA	
1-15	Prep Kitchen	Sink 1	1 <sup>ST</sup> DRAW	
1-16	"	"	2 <sup>ND</sup> DRAW	
1-17	Prep Kitchen	Sink 2	1 <sup>ST</sup> DRAW	
1-18	"	"	2 <sup>ND</sup> DRAW	
1-19	Prep Kitchen	Sink 3	1 <sup>ST</sup> DRAW	
1-20	"	"	2 <sup>ND</sup> DRAW	
1-21	305	cross sink	1 <sup>ST</sup> DRAW	
1-22	"	"	2 <sup>ND</sup> DRAW	
1-23	girls bath	Sink	1 <sup>ST</sup> DRAW	
1-24	"	"	2 <sup>ND</sup> DRAW	
1-25	boys bath	Sink	1 <sup>ST</sup> DRAW	
1-26	"	"	2 <sup>ND</sup> DRAW	
1-27	202	Sink	1 <sup>ST</sup> DRAW	
1-28	"	"	2 <sup>ND</sup> DRAW	
1-29	nurse office	Sink	1 <sup>ST</sup> DRAW	
1-30	"	"	2 <sup>ND</sup> DRAW	
1-31	boys bath	2nd floor	1 <sup>ST</sup> DRAW	
1-32	"	"	2 <sup>ND</sup> DRAW	
1-33	girls bath	2nd floor	1 <sup>ST</sup> DRAW	
1-34	"	"	2 <sup>ND</sup> DRAW	

TAKEN AND RELINQUISHED BY:

AHIRON SUSHOLZ

Signature

DATE: 7 15 / 25 /

Lexus Staffeld  
Accurate Analytical Testing

1183101



JUL 16 2025





AAA LEAD PROFESSIONALS  
6 WHITE DOVE CT  
LAKEWOOD NJ 08701  
732-668-9078

SAME DAY	24 HR TAT	48 HR TAT	72 HR TAT

# CHAIN OF CUSTODY

ADDRESS: 544 Chestnut Ave Trenton NJ

SAMPLE	ROOM	PLACE	AREA	
1-35	Staff bath	girls	1 <sup>ST</sup> DRAW	
1-36			2 <sup>ND</sup> DRAW	
1-37	mens bath	Staff	1 <sup>ST</sup> DRAW	
1-38			2 <sup>ND</sup> DRAW	
			1 <sup>ST</sup> DRAW	
			2 <sup>ND</sup> DRAW	
			1 <sup>ST</sup> DRAW	
			2 <sup>ND</sup> DRAW	
			1 <sup>ST</sup> DRAW	
			2 <sup>ND</sup> DRAW	
			1 <sup>ST</sup> DRAW	
			2 <sup>ND</sup> DRAW	
			1 <sup>ST</sup> DRAW	
			2 <sup>ND</sup> DRAW	
			1 <sup>ST</sup> DRAW	
			2 <sup>ND</sup> DRAW	
			1 <sup>ST</sup> DRAW	
			2 <sup>ND</sup> DRAW	

TAKEN AND RELINQUISHED BY:

AHRON SUSHOLZ

Signature

DATE: 7 15 / 25 /