



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)719-5649 Fax – (732)358-0168
Cert # 00407A Cert # 00430E
Asb # 01200

08/04/2026

Re: 171 Division St., Trenton, NJ 08611

To whom it may concern,

We have sampled the drinking water at the above property for lead and copper. Please note the Federal Action for Copper is 1,300 ug/l (ppb) and for lead is 15 ug/l (ppb).

The following results were found to be above the action level for lead:

- Kitchen Room 104 Sink 2 1st Draw

Feel Free to contact us with any questions.

Ariel Kinsbursky
(732)719-5649



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 1321429
Sampling Date : 07/24/2026
Date Received : 07/28/2026
Date Analyzed : 07/30/2026
Date Reported : 08/04/2026

Client Project : 171 DIVISION TRENTON NJ **Collected By :** ARIEL KINSBURSKY
Project Location : 171 DIVISION TRENTON NJ

WSSN : NP

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
11710668	25	KIT RM 104 SINK 1 1ST DRAW	NA		<0.0020	0.0020	Below
11710669	26	KIT RM 104 SINK 1 2ND DRAW	NA		<0.0020	0.0020	Below
11710670	27	KIT RM 104 SINK 2 1ST DRAW	NA		0.0287	0.0020	Above
11710671	28	KIT RM 104 SINK 2 2ND DRAW	NA		0.0089	0.0020	Below
11710672	29	BOYS BATH SINK 1ST DRAW	NA		0.0031	0.0020	Below
11710673	30	BOYS BATH SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710674	31	TCHRS LNG SINK 1ST DRAW	NA		0.0040	0.0020	Below
11710675	32	TCHRS LNG SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710676	33	WMN BATH SINK 1ST DRAW	NA		<0.0020	0.0020	Below
11710677	34	WMN BATH SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710678	35	201A SINK 1ST DRAW	NA		0.0105	0.0020	Below
11710679	36	201A SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710680	37	103 BATH SINK 1ST DRAW	NA		0.0020	0.0020	Below
11710681	38	103 BATH SINK 2ND DRAW	NA		<0.0020	0.0020	Below

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A "<" indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 mg/L for Pb and 1.3 mg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 08/04/2026

AAT Project: 1321429

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
-----------	-------------	--------------------	---------	-----------------	-------------------------	-----------------	--------------

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 mg/L for Pb and 1.3 mg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 08/04/2026

AAT Project: 1321429



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 1321429
Sampling Date : 07/24/2026
Date Received : 07/28/2026
Date Analyzed : 07/30/2026
Date Reported : 08/04/2026

Client Project : 171 DIVISION TRENTON NJ
Project Location : 171 DIVISION TRENTON NJ

Collected By : ARIEL KINSBURSKY

WSSN : NP

Sample ID	Client Code	Sample Description	Purpose	Collection Tim	Results Copper mg/L (ppm)	Cu Threshold
11710668	25	KIT RM 104 SINK 1 1ST DRAW	NA		0.0642	Below
11710669	26	KIT RM 104 SINK 1 2ND DRAW	NA		0.0393	Below
11710670	27	KIT RM 104 SINK 2 1ST DRAW	NA		0.0549	Below
11710671	28	KIT RM 104 SINK 2 2ND DRAW	NA		0.0401	Below
11710672	29	BOYS BATH SINK 1ST DRAW	NA		0.0319	Below
11710673	30	BOYS BATH SINK 2ND DRAW	NA		0.0380	Below
11710674	31	TCHRS LNG SINK 1ST DRAW	NA		0.0421	Below
11710675	32	TCHRS LNG SINK 2ND DRAW	NA		0.0381	Below
11710676	33	WMN BATH SINK 1ST DRAW	NA		0.0394	Below
11710677	34	WMN BATH SINK 2ND DRAW	NA		0.0402	Below
11710678	35	201A SINK 1ST DRAW	NA		0.1509	Below
11710679	36	201A SINK 2ND DRAW	NA		0.0382	Below
11710680	37	103 BATH SINK 1ST DRAW	NA		0.0472	Below
11710681	38	103 BATH SINK 2ND DRAW	NA		0.0367	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit. The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 mg/L for Pb and 1.3 mg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 08/04/2026

AAT Project: 1321429



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Attn : Joseph Perlstein

Email : joe@aaaleadpro.com

Phone : 732-668-9078

Project Location : 171 DIVISION TRENTON NJ

AAT Project : 1321429

Client Project : 171 DIVISION TRENTON NJ

Date Reported 08/04/2026

Sample	Client Code	Analysis Requested	Completed	Analyst
11710668	25	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710669	26	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710670	27	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710671	28	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710672	29	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710673	30	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710674	31	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710675	32	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710676	33	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710677	34	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710678	35	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710679	36	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710680	37	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710681	38	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise

Reviewed By

Elyse Bidle
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

NY State DOH ELAP -Lab ID #11864, Michigan State Lab # 9996

Date Printed: 08/04/2026 4:09AM

AAT Project: 1321429

Lead 1 Cooper



AAA LEAD PROFESSIONALS
6 WHITE DOVE CT
LAKEWOOD NJ 08701
732-668-9078

SAME DAY	24 HR TAT	48 HR TAT	72 HR TAT

CHAIN OF CUSTODY

ADDRESS: 171 DIVISION ST TRENTON NJ

11710068

SAMPLE	ROOM	PLACE	AREA	
25	KITCHEN ROOM 104	SINK 1	1 ST DRAW	
26	"	"	2 ND DRAW	
27	KITCHEN ROOM 104	SINK 2	1 ST DRAW	
28	"	"	2 ND DRAW	
29	BOYS BATH	SINK	1 ST DRAW	
30	"	"	2 ND DRAW	
31	TEACHERS LOUNGE	SINK	1 ST DRAW	
32	"	"	2 ND DRAW	
33	WOMEN BATH	SINK	1 ST DRAW	
34	"	"	2 ND DRAW	
35	201A	SINK	1 ST DRAW	
36	"	"	2 ND DRAW	
37	103 BATH	SINK	1 ST DRAW	
38	"	"	2 ND DRAW	

TAKEN AND RELINQUISHED BY:

ARIEL KINSBURSKY

A. Kinsbursky

Signature

DATE: 7/24/2026

Lexus Staffeld
Accurate Analytical Testing

JUL 28 2026

13d1489

