



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)719-5649 Fax – (732)358-0168
Cert # 00407A Cert # 00430E
Asb # 01200

08/04/2026

Re: 544 Chestnut Ave, Trenton, NJ 08611

To whom it may concern,

We have sampled the drinking water at the above property for lead and copper. Please note the Federal Action for Copper is 1,300 ug/l (ppb) and for lead is 15 ug/l (ppb).

The following results were found to be above the action level for lead:

- PREP KITCHEN SINK 2 1ST DRAW

Feel Free to contact us with any questions.

A. Kinsbursky

Ariel Kinsbursky
(732)719-5649



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 1321428
Sampling Date : 07/24/2026
Date Received : 07/28/2026
Date Analyzed : 08/03/2026
Date Reported : 08/04/2026

Client Project : 544 CHESTNUT AVE TRENTON
Project Location : 544 CHESTNUT AVE TRENTON NJ
Collected By : ARIEL KINSBURSKY

WSSN : NP

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
11710644	1	PREP KIT SINK 1 1ST DRAW	NA		<0.0020	0.0020	Below
11710645	2	PREP KIT SINK 1 2ND DRAW	NA		<0.0020	0.0020	Below
11710646	3	PREP KIT SINK 2 1ST DRAW	NA		0.0211	0.0020	Above
11710647	4	PREP KIT SINK 2 2ND DRAW	NA		<0.0020	0.0020	Below
11710648	5	PREP KIT SINK 3 1ST DRAW	NA		<0.0020	0.0020	Below
11710649	6	PREP KIT SINK SINK 3 2ND DRAW	NA		<0.0020	0.0020	Below
11710650	7	MAIN STAFF BATH SINK 1ST DRAW	NA		<0.0020	0.0020	Below
11710651	8	MAIN STAFF BATH SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710652	9	GIRLS BATH 2 FL SINK 1ST DRAW	NA		<0.0020	0.0020	Below
11710653	10	GIRLS BATH 2 FL SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710654	11	BOYS BATH 2 FL SINK 1ST DRAW	NA		<0.0020	0.0020	Below
11710655	12	BOYS BATH 2 FL SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710656	13	BOYS BATH 1 FL SINK 1ST DRAW	NA		0.0055	0.0020	Below
11710657	14	BOYS BATH 1 FL SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710658	15	GIRLS BATH 1 FL SINK 1ST DRAW	NA		<0.0020	0.0020	Below

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A "<" indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 mg/L for Pb and 1.3 mg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 08/04/2026

AAT Project: 1321428

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
11710659	16	GIRLS BATH 1 FL SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710660	17	202 SINK 1ST DRAW	NA		0.0025	0.0020	Below
11710661	18	202 SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710662	19	NURSE OFF SINK 1ST DRAW	NA		0.0077	0.0020	Below
11710663	20	NURSE OFF SINK 2ND DRAW	NA		<0.0020	0.0020	Below
11710664	21	STAFF BATH MEN 1 FL SINK 1ST DRAW	NA		<0.0020	0.0020	Below
11710665	22	STAFF BATH MEN 1 FL SINK 2ND DRAW	NA		0.0025	0.0020	Below
11710666	23	STAFF BATH WMN 1 FL SINK 1ST DRAW	NA		<0.0020	0.0020	Below
11710667	24	STAFF BATH WMN 1 FL SINK 2ND DRAW	NA		<0.0020	0.0020	Below

Analyst Signature



Joseph Kenwabikise



Zachary St John

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 mg/L for Pb and 1.3 mg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 1321428
Sampling Date : 07/24/2026
Date Received : 07/28/2026
Date Analyzed : 08/03/2026
Date Reported : 08/04/2026

Client Project : 544 CHESTNUT AVE TRENTON NJ **Collected By :** ARIEL KINSBURSKY
Project Location : 544 CHESTNUT AVE TRENTON NJ

WSSN : NP

Sample ID	Client Code	Sample Description	Purpose	Collection Tim	Results Copper mg/L (ppm)	Cu Threshold
11710644	1	PREP KIT SINK 1 1ST DRAW	NA		0.0370	Below
11710645	2	PREP KIT SINK 1 2ND DRAW	NA		0.0439	Below
11710646	3	PREP KIT SINK 2 1ST DRAW	NA		0.1819	Below
11710647	4	PREP KIT SINK 2 2ND DRAW	NA		0.0470	Below
11710648	5	PREP KIT SINK 3 1ST DRAW	NA		0.0368	Below
11710649	6	REP KIT SINK SINK 3 2ND DRA	NA		0.0451	Below
11710650	7	JIN STAFF BATH SINK 1ST DR	NA		0.0624	Below
11710651	8	JIN STAFF BATH SINK 2ND DR	NA		0.0547	Below
11710652	9	RLS BATH 2 FL SINK 1ST DRA	NA		0.1106	Below
11710653	10	RLS BATH 2 FL SINK 2ND DRA	NA		0.0230	Below
11710654	11	OYS BATH 2 FL SINK 1ST DRA	NA		0.0578	Below
11710655	12	OYS BATH 2 FL SINK 2ND DRA	NA		0.0259	Below
11710656	13	OYS BATH 1 FL SINK 1ST DRA	NA		0.0364	Below
11710657	14	OYS BATH 1 FL SINK 2ND DRA	NA		0.0352	Below
11710658	15	RLS BATH 1 FL SINK 1ST DRA	NA		0.0422	Below
11710659	16	RLS BATH 1 FL SINK 2ND DRA	NA		0.0328	Below
11710660	17	202 SINK 1ST DRAW	NA		0.1812	Below
11710661	18	202 SINK 2ND DRAW	NA		0.0469	Below
11710662	19	NURSE OFF SINK 1ST DRAW	NA		0.1580	Below
11710663	20	NURSE OFF SINK 2ND DRAW	NA		0.0617	Below

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit. The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A "<" indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 mg/L for Pb and 1.3 mg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 08/04/2026

AAT Project: 1321428

Sample ID	Client Code	Sample Description	Purpose	Collection Tim	Results Copper mg/L (ppm)	Cu Threshold
11710664	21	F BATH MEN 1 FL SINK 1ST D	NA		0.0108	Below
11710665	22	F BATH MEN 1 FL SINK 2ND C	NA		0.0482	Below
11710666	23	F BATH WMN 1 FL SINK 1ST C	NA		0.0062	Below
11710667	24	F BATH WMN 1 FL SINK 2ND C	NA		0.0352	Below

Analyst Signature



Joseph Kenwabikise



Zachary St John

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm). A '<' indicates the reported result is below AAT's reporting limit. For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated. EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu ; MI Regulatory Limits: 0.012 mg/L for Pb and 1.3 mg/L for Cu. The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Attn : Joseph Perlstein

Email : joe@aaaleadpro.com

Phone : 732-668-9078

Project Location : 544 CHESTNUT AVE TRENTON NJ

AAT Project : 1321428

Client Project : 544 CHESTNUT AVE TRENTON

Date Reported 08/04/2026

Sample	Client Code	Analysis Requested	Completed	Analyst
11710644	1	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710645	2	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710646	3	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710647	4	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710648	5	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710649	6	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710650	7	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710651	8	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710652	9	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710653	10	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710654	11	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710655	12	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710656	13	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710657	14	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710658	15	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710659	16	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710660	17	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710661	18	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710662	19	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710663	20	Pb/Cu in Drinking Water	08/03/2026	Zachary St John
11710664	21	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710665	22	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710666	23	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise
11710667	24	Pb/Cu in Drinking Water	07/30/2026	Joseph Kenwabikise

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

NY State DOH ELAP -Lab ID #11864, Michigan State Lab # 9996

Date Printed: 08/04/2026 4:09AM

AAT Project: 1321428

Sample	Client Code	Analysis Requested	Completed	Analyst
--------	-------------	--------------------	-----------	---------



Reviewed By

Elyse Bidle
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

Lead
Cooper



LEAD PROFESSIONALS

aaaleadpro.com

AAA LEAD PROFESSIONALS
6 WHITE DOVE CT
LAKEWOOD NJ 08701
732-668-9078

SAME DAY	24 HR TAT	48 HR TAT	72 HR TAT

CHAIN OF CUSTODY

ADDRESS: 544 CHESTNUT AVE TRENTON NJ

11710644

SAMPLE	ROOM	PLACE	AREA	
1	PREP KITCHEN	SINK 1	1 ST DRAW	
2	"	"	2 ND DRAW	
3	PREP KITCHEN	SINK 2	1 ST DRAW	
4	"	"	2 ND DRAW	
5	PREP KITCHEN	SINK 3	1 ST DRAW	
6	"	"	2 ND DRAW	
7	MAIN STAFF BATH	SINK	1 ST DRAW	
8	"	"	2 ND DRAW	
9	GIRLS BATH 2 ND FLOOR	SINK	1 ST DRAW	
10	"	"	2 ND DRAW	
11	BOYS BATH 2 ND FLOOR	SINK	1 ST DRAW	
12	"	"	2 ND DRAW	
13	BOYS BATH 1 ST FLOOR	SINK	1 ST DRAW	
14	"	"	2 ND DRAW	
15	GIRLS BATH 1 ST FLOOR	SINK	1 ST DRAW	
16	"	"	2 ND DRAW	
17	202	SINK	1 ST DRAW	
18	"	"	2 ND DRAW	
19	NURSE OFFICE	SINK	1 ST DRAW	
20	"	"	2 ND DRAW	
21	STAFF BATH MEN 1 ST FLOOR	SINK	1 ST DRAW	
22	"	"	2 ND DRAW	

AAT



240721

Lexus Staffeld
Accurate Analytical Testing

JUL 28 2026

1321478

23	STAFF BATH WOMEN 1 ST FLOOR	SINK	1 ST DRAW	
24	“	“	2 ND DRAW	

TAKEN AND RELINQUISHED BY:

ARIEL KINSBURSKY A. Kinsbursky DATE: 7 /24 /2026
Signature