



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)719-5649 Fax – (732)358-0168
Cert # 00407A Cert # 00430E

07/17/2024

Re: 171 Division St Trenton NJ 08611

To whom it may concern,

We have sampled the drinking water at the above property for lead. Please note the Federal Action Level for Copper is 1,300 ug/l (ppb) and for lead is 15 ug/l (ppb). All copper results were found to be below the action level.

The following lead results were found to be above the action level:

- Staff Bathroom 1st Draw
- Room 210 1st Draw
- Room 105 1st Draw
- Room 105 2nd Draw

Thank you very much.

Sincerely,

Joseph Perlstein

REVISED REPORT

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Attn : Joseph Perlstein Email : joe@aaaleadpro.com
Phone : 732-668-9078 Fax :

AAT Project : 1046038
Sampling Date : 07/08/2024
Date Received : 07/10/2024
Date Analyzed : 07/12/2024
Date Reported : 07/17/2024

Client Project : 171 DIVISION ST TRENTON N Collected By:

WSSN : NP

Project Location : 171 DIVISION ST TRENTON NJ

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
9555359	171-1	STAFF BTHRM 1ST DRAW	NA	NA	0.0152	0.0020	Above
9555360	171-2	STAFF BTHRM 2ND DRAW	NA	NA	0.0032	0.0020	Below
9555361	171-3	RM 210 1ST DRAW	NA	NA	0.0317	0.0020	Above
9555362	171-4	RM 210 2ND DRAW	NA	NA	<0.0020	0.0020	Below
9555363	171-7	BOYS BATH 1ST FL 1ST DRAW	NA	NA	0.0100	0.0020	Below
9555364	171-8	BOYS BATH 1ST FL 2ND DRAW	NA	NA	<0.0020	0.0020	Below
9555365	171-9	RM 105 1ST DRAW	NA	NA	0.2129	0.0020	Above
9555366	171-10	RM 105 2ND DRAW	NA	NA	0.0333	0.0020	Above
9555367	171-11	RM 103 NURSE OFFICE 1ST DRAW	NA	NA	0.0033	0.0020	Below
9555368	171-12	RM 103 NURSE OFFICE 2ND DRAW	NA	NA	<0.0020	0.0020	Below
9555369	171-13	RM 104 KITCHEN 1ST DRAW	NA	NA	0.0033	0.0020	Below
9555370	171-14	RM 104 KITCHEN 2ND DRAW	NA	NA	<0.0020	0.0020	Below

Analyst Signature



Nathan Ditty

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

REVISED REPORT

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

Attn : Joseph Perlstein Email : joe@aaaleadpro.com
 Phone : 732-668-9078 Fax :

AAT Project : 1046038
 Sampling Date : 07/08/2024
 Date Received : 07/10/2024
 Date Analyzed : 07/25/2024
 Date Reported : 07/17/2024

Client Project : 171 DIVISION ST TRENTON NJ Collected By :
 Project Location : 171 DIVISION ST TRENTON NJ

WSSN : NP

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
9555359	171-1	STAFF BTHRM 1ST DRAW	NA	NA	0.16926	Below
9555360	171-2	STAFF BTHRM 2ND DRAW	NA	NA	0.19856	Below
9555361	171-3	RM 210 1ST DRAW	NA	NA	0.16311	Below
9555362	171-4	RM 210 2ND DRAW	NA	NA	0.12365	Below
9555363	171-7	3OYS BATH 1ST FL 1ST DRAW	NA	NA	0.08614	Below
9555364	171-8	3OYS BATH 1ST FL 2ND DRAW	NA	NA	0.16014	Below
9555365	171-9	RM 105 1ST DRAW	NA	NA	0.5302	Below
9555366	171-10	RM 105 2ND DRAW	NA	NA	0.30831	Below
9555367	171-11	1 103 NURSE OFFICE 1ST DR	NA	NA	0.10526	Below
9555368	171-12	1 103 NURSE OFFICE 2ND DR	NA	NA	0.08352	Below
9555369	171-13	RM 104 KITCHEN 1ST DRAW	NA	NA	0.1341	Below
9555370	171-14	RM 104 KITCHEN 2ND DRAW	NA	NA	0.11233	Below

Analyst Signature

Nathan Ditty

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).
 For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 07/26/2024

AAT Project: 1046038



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

AAT Project : 1046038
Client Project : 171 DIVISION ST TRENTON N.
Date Reported : 07/17/2024

Attn : Joseph Perlstein Email : joe@aaaleadpro.com
Phone : 732-668-9078

Project Location : 171 DIVISION ST TRENTON NJ

Sample	Client Code	Analysis Requested	Completed	Analyst
9555359	171-1	Pb/Cu in Drinking Water	07/12/2024	Nathan Ditty
9555360	171-2	Pb/Cu in Drinking Water	07/12/2024	Nathan Ditty
9555361	171-3	Pb/Cu in Drinking Water	07/12/2024	Nathan Ditty
9555362	171-4	Pb/Cu in Drinking Water	07/12/2024	Nathan Ditty
9555363	171-7	Pb/Cu in Drinking Water	07/12/2024	Nathan Ditty
9555364	171-8	Pb/Cu in Drinking Water	07/12/2024	Nathan Ditty
9555365	171-9	Pb/Cu in Drinking Water	07/12/2024	Nathan Ditty
9555366	171-10	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555367	171-11	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555368	171-12	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555369	171-13	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555370	171-14	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty

Reviewed By

Elyse Bidle
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

Sample	Client Code	Analysis Requested	Completed	Analyst
Revision History				
Job #	Sample	Revision Date	Revised By	Comment
1046038	9555359	07/24/2024	Elyse Bidle	added Cu
1046038	9555360	07/24/2024	Elyse Bidle	added Cu
1046038	9555361	07/24/2024	Elyse Bidle	added Cu
1046038	9555362	07/24/2024	Elyse Bidle	added Cu
1046038	9555363	07/24/2024	Elyse Bidle	added Cu
1046038	9555364	07/24/2024	Elyse Bidle	added Cu
1046038	9555365	07/24/2024	Elyse Bidle	added Cu
1046038	9555366	07/24/2024	Elyse Bidle	added Cu
1046038	9555367	07/24/2024	Elyse Bidle	added Cu
1046038	9555368	07/24/2024	Elyse Bidle	added Cu
1046038	9555369	07/24/2024	Elyse Bidle	added Cu
1046038	9555370	07/24/2024	Elyse Bidle	added Cu
1046038	9555359	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis
1046038	9555360	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

Sample	Client Code	Analysis Requested	Completed	Analyst
1046038	9555361	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis
1046038	9555362	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis
1046038	9555363	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis
1046038	9555364	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis
1046038	9555365	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis
1046038	9555366	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis
1046038	9555367	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis
1046038	9555368	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis
1046038	9555369	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis
1046038	9555370	07/25/2024	Joseph Kenwabikise	Client wanted Cu analysis

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

