



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)719-5649 Fax – (732)358-0168
Cert # 00407A Cert # 00430E

07/17/2024

Re: 544 Chestnut St Trenton NJ 08611

To whom it may concern,

We have sampled the drinking water at the above property for lead. Please note the Federal Action Level for Copper is 1,300 ug/l (ppb) and for lead is 15 ug/l (ppb). All copper results were found to be below the action level.

The following lead results were found to be above the action level:

- Girls Bathroom 1st Fl, 1st Draw

Thank you very much.

Sincerely,

Joseph Perlstein



30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

REVISED REPORT

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

Attn : Joseph Perlstein Email : joe@aaaleadpro.com
 Phone : 732-668-9078 Fax :

AAT Project : 1046034
 Sampling Date : 07/08/2024
 Date Received : 07/10/2024
 Date Analyzed : 07/13/2024
 Date Reported : 07/16/2024

Client Project : 544 CHESTNUT AVE TRENTON Collected By: Joseph Perlstein

WSSN : NP

Project Location : 544 CHESTNUT AVE TRENTON NJ

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
9555335	544-1	BOYS BATH 3RD FL 1ST DRAW	NA	NA	0.0071	0.0020	Below
9555336	544-2	BOYS BATH 3RD FL 2ND DRAW	NA	NA	<0.0020	0.0020	Below
9555337	544-3	RM 305 1ST DRAW	NA	NA	0.0035	0.0020	Below
9555338	544-4	RM 305 2ND DRAW	NA	NA	0.0099	0.0020	Below
9555339	544-5	GIRLS BATH 3RD FL 1ST DRAW	NA	NA	0.0035	0.0020	Below
9555340	544-6	GIRLS BATH 3RD FL 2ND DRAW	NA	NA	0.0025	0.0020	Below
9555341	544-7	GIRLS BATH 2ND FL 1ST DRAW	NA	NA	0.0072	0.0020	Below
9555342	544-8	GIRLS BATH 2ND FL 2ND DRAW	NA	NA	0.0028	0.0020	Below
9555343	544-9	BOYS BATH 2ND FL 1ST DRAW	NA	NA	0.0048	0.0020	Below
9555344	544-10	BOYS BATH 2ND FL 2ND DRAW	NA	NA	0.0026	0.0020	Below
9555345	544-13	RM 202 1ST DRAW	NA	NA	0.0046	0.0020	Below
9555346	544-14	RM 202 2ND DRAW	NA	NA	0.0021	0.0020	Below
9555347	544-15	BOYS BATH 1ST FL 1ST DRAW	NA	NA	<0.0020	0.0020	Below
9555348	544-16	BOYS BATH 1ST FL 2ND DRAW	NA	NA	<0.0020	0.0020	Below
9555349	544-17	GIRLS BATH 1ST FL 1ST DRAW	NA	NA	0.0152	0.0020	Above

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).
 For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed.
 Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 07/24/2024

AAT Project: 1046034

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
9555350	544-18	GIRLS BATH 1ST FL 2ND DRAW	NA	NA	0.0033	0.0020	Below
9555351	544-19	STAFF WORK RM SINK 1 1ST DRAW	NA	NA	<0.0020	0.0020	Below
9555352	544-20	STAFF WORK RM SINK 2 2ND DRAW	NA	NA	0.0033	0.0020	Below
9555353	544-21	STAFF WORK RM SINK 2 1ST DRAW	NA	NA	0.0030	0.0020	Below
9555354	544-22	STAFF WORK RM SINK 2 2ND DRAW	NA	NA	0.0051	0.0020	Below
9555355	544-23	STAFF BATH 1ST FL 1ST DRAW	NA	NA	<0.0020	0.0020	Below
9555356	544-24	STAFF BATH 1ST FL 2ND DRAW	NA	NA	<0.0020	0.0020	Below

Analyst Signature

Joseph Kenwabikise

Nathan Ditty

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed.

Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

REVISED REPORT

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

Attn : Joseph Perlstein Email : joe@aaaleadpro.com
 Phone : 732-668-9078 Fax :

AAT Project : 1046034
 Sampling Date : 07/08/2024
 Date Received : 07/10/2024
 Date Analyzed : 07/24/2024
 Date Reported : 07/16/2024

Client Project : 544 CHESTNUT AVE TRENTON N Collected By : Joseph Perlstein
 Project Location : 544 CHESTNUT AVE TRENTON NJ

WSSN : NP

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
9555335	544-1	BOYS BATH 3RD FL 1ST DRAW	NA	NA	0.34905	Below
9555336	544-2	BOYS BATH 3RD FL 2ND DRAW	NA	NA	0.06019	Below
9555337	544-3	RM 305 1ST DRAW	NA	NA	0.10221	Below
9555338	544-4	RM 305 2ND DRAW	NA	NA	0.23435	Below
9555339	544-5	GIRLS BATH 3RD FL 1ST DRAW	NA	NA	0.01489	Below
9555340	544-6	GIRLS BATH 3RD FL 2ND DRAW	NA	NA	0.03177	Below
9555341	544-7	GIRLS BATH 2ND FL 1ST DRAW	NA	NA	0.22321	Below
9555342	544-8	GIRLS BATH 2ND FL 2ND DRAW	NA	NA	0.09600	Below
9555343	544-9	BOYS BATH 2ND FL 1ST DRAW	NA	NA	0.15526	Below
9555344	544-10	BOYS BATH 2ND FL 2ND DRAW	NA	NA	0.07205	Below
9555345	544-13	RM 202 1ST DRAW	NA	NA	0.26864	Below
9555346	544-14	RM 202 2ND DRAW	NA	NA	0.14656	Below
9555347	544-15	BOYS BATH 1ST FL 1ST DRAW	NA	NA	0.05672	Below
9555348	544-16	BOYS BATH 1ST FL 2ND DRAW	NA	NA	0.05442	Below
9555349	544-17	GIRLS BATH 1ST FL 1ST DRAW	NA	NA	0.31958	Below
9555350	544-18	GIRLS BATH 1ST FL 2ND DRAW	NA	NA	0.08186	Below
9555351	544-19	OFF WORK RM SINK 1 1ST DR	NA	NA	0.10729	Below
9555352	544-20	OFF WORK RM SINK 1 2ND DR	NA	NA	0.10895	Below
9555353	544-21	OFF WORK RM SINK 2 1ST DR	NA	NA	0.10571	Below
9555354	544-22	OFF WORK RM SINK 2 2ND DR	NA	NA	0.25312	Below

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).
 For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 07/24/2024

AAT Project: 1046034

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
9555355	544-23	STAFF BATH 1ST FL 1ST DRAW	NA	NA	0.19674	Below
9555356	544-24	STAFF BATH 1ST FL 2ND DRAW	NA	NA	0.13769	Below

Analyst Signature

Joseph Kenwabikise

Nathan Ditty

ND = Not Detected, N/A = Not Available, NP = Not Provided, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results

relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

AAT Project : 1046034
 Client Project : 544 CHESTNUT AVE TRENTON
 Date Reported : 07/16/2024

Attn : Joseph Perlstein Email : joe@aaaleadpro.com
 Phone : 732-668-9078

Project Location : 544 CHESTNUT AVE TRENTON NJ

Sample	Client Code	Analysis Requested	Completed	Analyst
9555335	544-1	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555336	544-2	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555337	544-3	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555338	544-4	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555339	544-5	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555340	544-6	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555341	544-7	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555342	544-8	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555343	544-9	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555344	544-10	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555345	544-13	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555346	544-14	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555347	544-15	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555348	544-16	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555349	544-17	Pb/Cu in Drinking Water	07/13/2024	Nathan Ditty
9555350	544-18	Pb/Cu in Drinking Water	07/11/2024	Joseph Kenwabikise
9555351	544-19	Pb/Cu in Drinking Water	07/11/2024	Joseph Kenwabikise
9555352	544-20	Pb/Cu in Drinking Water	07/11/2024	Joseph Kenwabikise
9555353	544-21	Pb/Cu in Drinking Water	07/11/2024	Joseph Kenwabikise
9555354	544-22	Pb/Cu in Drinking Water	07/11/2024	Joseph Kenwabikise
9555355	544-23	Pb/Cu in Drinking Water	07/11/2024	Joseph Kenwabikise
9555356	544-24	Pb/Cu in Drinking Water	07/11/2024	Joseph Kenwabikise

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.



Reviewed By

Elyse Bidle
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.



AAA LEAD PROFESSIONALS
 6 WHITE DOVE CT
 LAKEWOOD NJ 08701
 732-668-9078

SAME DAY	24 HR TAT	48 HR TAT	72 HR TAT

CHAIN OF CUSTODY

ADDRESS: 544 CHESTNUT AVE TRENTON NJ

9555335

SAMPLE	ROOM	PLACE	AREA
544-1	BOYS BATH 3 RD FLOOR	1 ST DRAW	
544-2	BOYS BATH 3 RD FLOOR	2 ND DRAW	
544-3	ROOM 305	1 ST DRAW	
544-4	ROOM 305	2 ND DRAW	
544-5	GIRLS BATH 3 RD FLOOR	1 ST DRAW	
544-6	GIRLS BATH 3 RD FLOOR	2 ND DRAW	
544-7	GIRLS BATH 2 ND FLOOR	1 ST DRAW	
544-8	GIRLS BATH 2 ND FLOOR	2 ND DRAW	
544-9	BOYS BATH 2 ND FLOOR	1 ST DRAW	
544-10	BOYS BATH 2 ND FLOOR	2 ND DRAW	
544-13	ROOM 202	1 ST DRAW	
544-14	ROOM 202	2 ND DRAW	
544-15	BOYS BATH 1 ST FLOOR	1 ST DRAW	
544-16	BOYS BATH 1 ST FLOOR	2 ND DRAW	
544-17	GIRLS BATH 1 ST FLOOR	1 ST DRAW	
544-18	GIRLS BATH 1 ST FLOOR	2 ND DRAW	
544-19	STAFF WORK ROOM	SINK 1 1 ST DRAW	
544-20	STAFF WORK ROOM	SINK 1 2 ND DRW	
544-21	STAFF WORK ROOM	SINK 2 1 ST DRAW	
544-22	STAFF WORK ROOM	SINK 2 2 ND DRW	
544-23	STAFF BATH 1 ST FLOOR	1 ST DRAW	
544-24	STAFF BATH 1 ST FLOOR	2 ND DRAW	

TAKEN AND RELINQUISHED BY:

JOSEPH PERLSTEIN

[Handwritten Signature]

DATE: 7/18/24

Signature
 Rebecca Davis
 urate Analytical Testing

JUL 10 2024

3192-1046034