



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)668-9078 Fax – (732)358-0168
Cert # 00407A Cert # 00430E
Asb # 01200

04/25/2023

Re: 171 DIVISION ST, TRENTON NJ 08611

To whom it may concern,

We have sampled the drinking water at the above property for copper and lead . Please note the Federal Action for copper is 1,300 ug/l (ppb) and lead is 15 ug/l (ppb).

The following lead results were found to be above the action level:

- STAFF BATHRM 1ST DRAW
- RM 104 KIT 1ST DRAW

All copper results were found to be below the action level.

Feel Free to contact us with any questions.

A. Kinsbursky

Ariel Kinsbursky
732-668-9078



30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 905137
Sampling Date : 04/17/2023
Date Received : 04/20/2023
Date Analyzed : 04/21/2023
Date Reported : 04/24/2023

Client Project : 171 DIVISION ST TRENTON N **Collected By:** ARIEL KINSBURSKY

WSSN :

Project Location : 171 DIVISION ST TRENTON NJ

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
8363697	171-1	STAFF BATHRM 1ST DRAW	NA	0	0.09466	0.0020	Above
8363698	171-2	STAFF BATHRM 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363699	171-3	RM 210 1ST DRAW	NA	0	0.0047	0.0020	Below
8363700	171-4	RM 210 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363701	171-5	RM 217 BATHRM 1ST DRAW	NA	0	0.0048	0.0020	Below
8363702	171-6	RM 217 BATHRM 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363703	171-7	BOYS BATH 1ST FLR 1ST DRAW	NA	0	0.0058	0.0020	Below
8363704	171-8	BOYS BATH 1ST FLR 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363705	171-9	RM 104 KIT 1ST DRAW	NA	0	0.0343	0.0020	Above
8363706	171-10	RM 104 KIT 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363707	171-11	RM 103 NURSE OFFICE 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363708	171-12	RM 103 NURSE OFFICE 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363709	171-13	RM 104 KIT SINK 1ST DRAW	NA	0	0.0020	0.0020	Below
8363710	171-14	RM 104 KIT SINK 2 2ND DRAW	NA	0	<0.0020	0.0020	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 04/24/2023

AAT Project: 905137

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
-----------	-------------	--------------------	---------	-----------------	-------------------------	-----------------	--------------

Analyst Signature


Nathan Ditty

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

Attn : Joseph Perlstein **Email :** joe@aaaleadpro.com
Phone : 732-668-9078 **Fax :**

AAT Project : 905137
Sampling Date : 04/17/2023
Date Received : 04/20/2023
Date Analyzed : 04/21/2023
Date Reported : 04/24/2023

Client Project : 171 DIVISION ST TRENTON NJ **Collected By :** ARIEL KINSBURSKY
Project Location : 171 DIVISION ST TRENTON NJ

WSSN :

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
8363697	171-1	STAFF BATHRM 1ST DRAW	NA	0	0.1229	Below
8363698	171-2	STAFF BATHRM 2ND DRAW	NA	0	0.0283	Below
8363699	171-3	RM 210 1ST DRAW	NA	0	0.0843	Below
8363700	171-4	RM 210 2ND DRAW	NA	0	0.0258	Below
8363701	171-5	RM 217 BATHRM 1ST DRAW	NA	0	0.0527	Below
8363702	171-6	RM 217 BATHRM 2ND DRAW	NA	0	0.0318	Below
8363703	171-7	OYS BATH 1ST FLR 1ST DRAW	NA	0	0.0389	Below
8363704	171-8	OYS BATH 1ST FLR 2ND DRAW	NA	0	0.0262	Below
8363705	171-9	RM 104 KIT 1ST DRAW	NA	0	0.0949	Below
8363706	171-10	RM 104 KIT 2ND DRAW	NA	0	0.0243	Below
8363707	171-11	1103 NURSE OFFICE 1ST DRAW	NA	0	0.0444	Below
8363708	171-12	1103 NURSE OFFICE 2ND DRAW	NA	0	0.0288	Below
8363709	171-13	RM 104 KIT SINK 1ST DRAW	NA	0	0.1171	Below
8363710	171-14	RM 104 KIT SINK 2 2ND DRAW	NA	0	0.0313	Below

Analyst Signature



Nathan Ditty

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).
 For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals
 6 White Dove Court
 Lakewood, NJ 08701

AAT Project : 905137
 Client Project : 171 DIVISION ST TRENTON N.
 Date Reported : 04/24/2023

Attn : Joseph Perlstein Email : joe@aaaleadpro.com
 Phone : 732-668-9078

Project Location : 171 DIVISION ST TRENTON NJ

Sample	Client Code	Analysis Requested	Completed	Analyst
8363697	171-1	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363698	171-2	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363699	171-3	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363700	171-4	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363701	171-5	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363702	171-6	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363703	171-7	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363704	171-8	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363705	171-9	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363706	171-10	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363707	171-11	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363708	171-12	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363709	171-13	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty
8363710	171-14	Pb/Cu in Drinking Water	04/21/2023	Nathan Ditty

Reviewed By

Elyse Bidle
 Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

AAA LEAD PROFESSIONALS
6 WHITE DOVE CT
LAKEWOOD NJ 08701
732-668-9078

72 HR

CHAIN OF CUSTODY

171 DIVISION ST TRENTON NJ

Lead & Copper

8763697

SAMPLE	ROOM	PLACE	AREA	
171-1	STAFF BATHROOM	1ST DRAW		
171-2	STAFF BATHROOM	2ND DRAW		
171-3	ROOM 210	1ST DRAW		
171-4	ROOM 210	2ND DRAW		
171-5	RM 217 BATHROOM	1ST DRAW		
171-6	RM 217 BATHROOM	2ND DRAW		
171-7	BOYS BATH 1ST FLR	1ST DRAW		
171-8	BOYS BATH 1ST FLR	2ND DRAW		
171-9	RM 104 KITCHEN	1ST DRAW		
171-10	RM 104 KITCHEN	2ND DRAW		
171-11	RM 103 NURSE OFFICE	1ST DRAW		
171-12	RM 103 NURSE OFFICE	2ND DRAW		
171-13	RM 104 KITCHEN	SINK 2 1ST DRAW		

171-14 RM 104 Kitchen Sink 2 2ND DRAW

TAKEN AND RELINQUISHED BY ARIEL KINSBURSKY

DATE: 4/17/2023

A. Kinsbursky

APR 20 2023

3192
905137