



6 White Dove Ct. Lakewood NJ 08701  
Tel- (732)668-9078 Fax – (732)358-0168  
Cert # 00407A Cert # 00430E  
Asb # 01200

---

04/25/2023

Re: 520 CHESTNUT AVE TRENTON NJ 08611

To whom it may concern,

We have sampled the drinking water at the above property for copper and lead . Please note the Federal Action for copper is 1,300 ug/l (ppb) and lead is 15 ug/l (ppb).

The following lead results were found to be above the action level:

- Rm 113 Right 1st Draw
- Rm 113 Left 1st Draw
- Boys Bath Right 1st Draw
- Boys Bath Left 2nd Draw
- Staff Bath 2nd Flr 1st Draw
- Girls Bath Bstm Sink 1 1st Draw
- Girls Bath Bstm Sink 2 1st Draw
- Girls Bath Bsmt Sink 3 1st Draw
- Girls Bath Bsmt Sink 3 2st Draw
- Girls Bath Bsmt Sink 4 1st Draw
- Boys Bath Bstm Sink 1 1st Draw
- Boys Bath Bstm Sink 1 2nd Draw
- Boys Bath Bstm Sink 3 1st Draw

The following copper results were found to be above the action level:

- Rm 113 Left 1st Draw
- Rm 202 1st Draw

Feel Free to contact us with any questions.

*A. Kinsbursky*

Ariel Kinsbursky  
732-668-9078



30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-629-8161; Fax: 734-629-8431

## Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

**Client :** AAA Lead Professionals  
 6 White Dove Court  
 Lakewood, NJ 08701

**Attn :** Joseph Perlstein      **Email :** joe@aaaleadpro.com  
**Phone :** 732-668-9078      **Fax :**

**AAT Project :** 905138  
**Sampling Date :** 04/17/2023  
**Date Received :** 04/20/2023  
**Date Analyzed :** 04/21/2023  
**Date Reported :** 04/25/2023

**Client Project :** 520 CHESTNUT AVE TRENTON      **Collected By :** ARIEL KINSBURSKY

**WSSN :**


**Project Location :** 520 CHESTNUT AVE TRENTON NJ

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
8363711	520-1	RM 113 RIGHT 1ST DRAW	NA	0	0.0933	0.0020	Above
8363712	520-2	RM 113 RIGHT 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363713	520-3	RM 113 LEFT 1ST DRAW	NA	0	0.1290	0.0020	Above
8363714	520-4	RM 113 LEFT 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363715	520-5	KIT SINK 1 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363716	520-6	KIT SINK 1 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363717	520-7	KIT SINK 2 1ST DRAW	NA	0	0.0048	0.0020	Below
8363718	520-8	KIT SINK 2 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363719	520-9	KIT SINK 3 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363720	520-10	KIT SINK 3 2ST DRAW	NA	0	<0.0020	0.0020	Below
8363721	520-11	KIT SINK 4 1ST DRAW	NA	0	0.0047	0.0020	Below
8363722	520-12	KIT SINK 4 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363723	520-13	BOYS BATH RIGHT 1ST DRAW	NA	0	0.0201	0.0020	Above
8363724	520-14	BOYS BATH RIGHT 2ND DRAW	NA	0	0.0035	0.0020	Below
8363725	520-15	BOYS BATH LEFT 1ST DRAW	NA	0	0.0029	0.0020	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.  
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 04/25/2023

AAT Project: 905138

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
8363726	520-16	BOYS BATH LEFT 2ND DRAW	NA	0	0.01800	0.0020	Above
8363727	520-17	GIRLS BATH RIGHT 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363728	520-18	GIRLS BATH RIGHT 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363729	520-19	GIRLS BATH LEFT 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363730	520-20	GIRLS BATH LEFT 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363731	520-21	STAFF BATH 1ST DRAW	NA	0	0.0022	0.0020	Below
8363732	520-22	STAFF BATH 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363733	520-23	RM 102 1ST DRAW	NA	0	0.0068	0.0020	Below
8363734	520-24	RM 102 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363735	520-25	CUSTODIAL RM 1ST DRAW	NA	0	0.0020	0.0020	Below
8363736	520-26	CUSTODIAL RM 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363737	520-27	RM 202 1ST DRAW	NA	0	0.0128	0.0020	Below
8363738	520-28	RM 202 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363739	520-29	CUSTODIAL CLOSET 1ST DRAW	NA	0	0.0108	0.0020	Below
8363740	520-30	CUSTODIAL CLOSET 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363741	520-31	RM 209 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363742	520-32	RM 209 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363743	520-33	STAFF BATH 2ND FLR 1ST DRAW	NA	0	0.0174	0.0020	Above
8363744	520-34	STAFF BATH 2ND FLR 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363745	520-35	RM 207 1ST DRAW	NA	0	0.0067	0.0020	Below
8363746	520-36	RM 207 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363747	520-37	GIRLS BATH BSTM SINK 1 1ST DRAW	NA	0	0.0612	0.0020	Above
8363748	520-38	GIRLS BATH BSMT SINK 1 2ND DRAW	NA	0	<0.0020	0.0020	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed.

Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
8363749	520-39	GIRLS BATH BSTM SINK 2 1ST DRAW	NA	0	0.1211	0.0020	Above
8363750	520-40	GIRLS BATH BSMT SINK 2 2ND DRAW	NA	0	0.0122	0.0020	Below
8363751	520-41	GIRLS BATH BSMT SINK 3 1ST DRA	NA	0	0.6992	0.0020	Above
8363752	520-42	GIRLS BATH BSMT SINK 3 2ST DRAW	NA	0	0.1372	0.0020	Above
8363753	520-43	GIRLS BATH BSMT SINK 4 1ST DRAW	NA	0	0.0199	0.0020	Above
8363754	520-44	GIRLS BATH BSTM SINK 4 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363755	520-45	BOYS BATH BSTM SINK 1 1ST DRAW	NA	0	0.04533	0.0020	Above
8363756	520-46	BOYS BATH BSTM SINK 1 2ND DRAW	NA	0	0.0265	0.0020	Above
8363757	520-47	BOYS BATH BSMT SINK 2 1ST DRAW	NA	0	0.0039	0.0020	Below
8363758	520-48	BOYS BATH BSTM SINK 2 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363759	520-49	BOYS BATH BSTM SINK 3 1ST DRAW	NA	0	0.0214	0.0020	Above
8363760	520-50	BOYS BATH BSMT SINK 3 2ST DRAW	NA	0	<0.0020	0.0020	Below

Analyst Signature

Joseph Kenwabikise

Nathan Ditty

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-629-8161; Fax: 734-629-8431

## Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

**Client :** AAA Lead Professionals  
 6 White Dove Court  
 Lakewood, NJ 08701

**Attn :** Joseph Perlstein      **Email :** joe@aaaleadpro.com  
**Phone :** 732-668-9078      **Fax :**

**AAT Project :** 905138  
**Sampling Date :** 04/17/2023  
**Date Received :** 04/20/2023  
**Date Analyzed :** 04/21/2023  
**Date Reported :** 04/25/2023

**Client Project :** 520 CHESTNUT AVE TRENTON N      **Collected By :** ARIEL KINSBURSKY  
**Project Location :** 520 CHESTNUT AVE TRENTON NJ

**WSSN :**

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
8363711	520-1	RM 113 RIGHT 1ST DRAW	NA	0	1.2223	Below
8363712	520-2	RM 113 RIGHT 2ND DRAW	NA	0	0.0470	Below
8363713	520-3	RM 113 LEFT 1ST DRAW	NA	0	4.4511	Above
8363714	520-4	RM 113 LEFT 2ND DRAW	NA	0	0.0657	Below
8363715	520-5	KIT SINK 1 1ST DRAW	NA	0	0.0617	Below
8363716	520-6	KIT SINK 1 2ND DRAW	NA	0	0.0596	Below
8363717	520-7	KIT SINK 2 1ST DRAW	NA	0	0.2969	Below
8363718	520-8	KIT SINK 2 2ND DRAW	NA	0	0.0668	Below
8363719	520-9	KIT SINK 3 1ST DRAW	NA	0	0.0244	Below
8363720	520-10	KIT SINK 3 2ST DRAW	NA	0	0.0439	Below
8363721	520-11	KIT SINK 4 1ST DRAW	NA	0	0.2827	Below
8363722	520-12	KIT SINK 4 2ND DRAW	NA	0	0.3989	Below
8363723	520-13	3OYS BATH RIGHT 1ST DRAW	NA	0	0.1365	Below
8363724	520-14	3OYS BATH RIGHT 2ND DRAW	NA	0	0.0490	Below
8363725	520-15	BOYS BATH LEFT 1ST DRAW	NA	0	0.0420	Below
8363726	520-16	BOYS BATH LEFT 2ND DRAW	NA	0	0.0431	Below
8363727	520-17	3IRLS BATH RIGHT 1ST DRAW	NA	0	0.1141	Below
8363728	520-18	3IRLS BATH RIGHT 2ND DRAW	NA	0	0.0442	Below
8363729	520-19	GIRLS BATH LEFT 1ST DRAW	NA	0	0.0154	Below
8363730	520-20	GIRLS BATH LEFT 2ND DRAW	NA	0	0.0286	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit. The Analytical Reporting Limit for Pb is 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results

relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted.

All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 04/25/2023

AAT Project: 905138

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
8363731	520-21	STAFF BATH 1ST DRAW	NA	0	0.2567	Below
8363732	520-22	STAFF BATH 2ND DRAW	NA	0	0.0304	Below
8363733	520-23	RM 102 1ST DRAW	NA	0	0.4680	Below
8363734	520-24	RM 102 2ND DRAW	NA	0	0.0398	Below
8363735	520-25	CUSTODIAL RM 1ST DRAW	NA	0	0.0683	Below
8363736	520-26	CUSTODIAL RM 2ND DRAW	NA	0	0.0346	Below
8363737	520-27	RM 202 1ST DRAW	NA	0	1.5049	Above
8363738	520-28	RM 202 2ND DRAW	NA	0	0.0857	Below
8363739	520-29	USTODIAL CLOSET 1ST DRAW	NA	0	0.8991	Below
8363740	520-30	USTODIAL CLOSET 2ND DRAW	NA	0	0.0358	Below
8363741	520-31	RM 209 1ST DRAW	NA	0	0.3916	Below
8363742	520-32	RM 209 2ND DRAW	NA	0	0.0356	Below
8363743	520-33	TAFF BATH 2ND FLR 1ST DRAW	NA	0	0.3019	Below
8363744	520-34	TAFF BATH 2ND FLR 1ST DRAW	NA	0	0.0458	Below
8363745	520-35	RM 207 1ST DRAW	NA	0	0.1557	Below
8363746	520-36	RM 207 2ND DRAW	NA	0	0.0363	Below
8363747	520-37	LS BATH BSTM SINK 1 1ST DF	NA	0	0.2524	Below
8363748	520-38	LS BATH BSMT SINK 1 2ND DF	NA	0	0.0382	Below
8363749	520-39	LS BATH BSTM SINK 2 1ST DF	NA	0	0.4141	Below
8363750	520-40	LS BATH BSMT SINK 2 2ND DF	NA	0	0.0696	Below
8363751	520-41	LS BATH BSMT SINK 3 1ST DF	NA	0	0.0927	Below
8363752	520-42	LS BATH BSMT SINK 3 2ST DF	NA	0	0.0493	Below
8363753	520-43	LS BATH BSMT SINK 4 1ST DF	NA	0	0.4219	Below
8363754	520-44	LS BATH BSTM SINK 4 2ND DF	NA	0	0.0436	Below
8363755	520-45	LS BATH BSTM SINK 1 1ST DF	NA	0	0.0473	Below
8363756	520-46	LS BATH BSTM SINK 1 2ND DF	NA	0	0.0376	Below
8363757	520-47	LS BATH BSMT SINK 2 1ST DF	NA	0	0.0416	Below
8363758	520-48	LS BATH BSTM SINK 2 2ND DF	NA	0	0.0313	Below
8363759	520-49	LS BATH BSTM SINK 3 1ST DF	NA	0	0.0802	Below
8363760	520-50	LS BATH BSMT SINK 3 2ST DF	NA	0	0.0304	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit. The Analytical Reporting Limit for Pb is 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results

relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted.

All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.




Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
---------------	-------------	--------------------	---------	-----------------	------------------------------	--------------

Analyst Signature

Joseph Kenwabikise

Nathan Ditty

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).  
 For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.  
 EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu  
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.







30105 Beverly Road  
Romulus, MI 48174  
Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals  
6 White Dove Court  
Lakewood, NJ 08701

AAT Project : 905138  
Client Project : 520 CHESTNUT AVE TRENTON  
Date Reported : 04/25/2023

Attn : Joseph Perlstein      Email : joe@aaaleadpro.com  
Phone : 732-668-9078

Project Location : 520 CHESTNUT AVE TRENTON NJ

Sample	Client Code	Analysis Requested	Completed	Analyst
8363711	520-1	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363712	520-2	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363713	520-3	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363714	520-4	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363715	520-5	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363716	520-6	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363717	520-7	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363718	520-8	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363719	520-9	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363720	520-10	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363721	520-11	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363722	520-12	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363723	520-13	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363724	520-14	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363725	520-15	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363726	520-16	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363727	520-17	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363728	520-18	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363729	520-19	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363730	520-20	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363731	520-21	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363732	520-22	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363733	520-23	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363734	520-24	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363735	520-25	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363736	520-26	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363737	520-27	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

Sample	Client Code	Analysis Requested	Completed	Analyst
8363738	520-28	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363739	520-29	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363740	520-30	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363741	520-31	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363742	520-32	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363743	520-33	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363744	520-34	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363745	520-35	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363746	520-36	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363747	520-37	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363748	520-38	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363749	520-39	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363750	520-40	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363751	520-41	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363752	520-42	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363753	520-43	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363754	520-44	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363755	520-45	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363756	520-46	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363757	520-47	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363758	520-48	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363759	520-49	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty
8363760	520-50	Pb/Cu in Drinking Water	04/24/2023	Nathan Ditty

**Reviewed By**

Elyse Bidle  
Quality Assurance Coordinator

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

A. AD PROFESSIONALS  
 6 WHITE DOVE CT  
 LAKEWOOD NJ 08701  
 732-668-9078

72 HR

CHAIN OF CUSTODY  
 369711

520 CHESTNUT AVE TRENTON NJ

Lead & Copper

SAMPLE	ROOM	PLACE	AREA	
520-1	ROOM 113	RIGHT 1ST DRAW		
520-2	ROOM 113	RIGHT 2ND DRAW		
520-3	ROOM 113	LEFT 1ST DRAW		
520-4	ROOM 113	LEFT 2ND DRAW		
520-5	KITCHEN	SINK 1 1ST DRAW		
520-6	KITCHEN	SINK 1 2ND DRAW		
520-7	KITCHEN	SINK 2 1ST DRAW		
520-8	KITCHEN	SINK 2 2ND DRAW		
520-9	KITCHEN	SINK 3 1ST DRAW		
520-10	KITCHEN	SINK 3 2ST DRAW		
520-11	KITCHEN	SINK 4 1ST DRAW		
520-12	KITCHEN	SINK 4 2ND DRAW		
520-13	BOYS BATH	RIGHT 1ST DRAW		
520-14	BOYS BATH	RIGHT 2ND DRAW		
520-15	BOYS BATH	LEFT 1ST DRAW		
520-16	BOYS BATH	LEFT 2ND DRAW		
520-17	GIRLS BATH	RIGHT 1ST DRAW		
520-18	GIRLS BATH	RIGHT 2ND DRAW		
520-19	GIRLS BATH	LEFT 1ST DRAW		
520-20	GIRLS BATH	LEFT 2ND DRAW		
520-21	STAFF BATH	1ST DRAW		
520-22	STAFF BATH	2ND DRAW		
520-23	ROOM 102	1ST DRAW		
520-24	ROOM 102	2ND DRAW		
520-25	CUSTODIAL ROOM	1ST DRAW		
520-26	CUSTODIAL ROOM	2ND DRAW		
520-27	ROOM 202	1ST DRAW		
520-28	ROOM 202	2ND DRAW		
520-29	CUSTODIAL CLOSET	1ST DRAW		
520-30	CUSTODIAL CLOSET	2ND DRAW		
520-31	ROOM 209	1ST DRAW		
520-32	ROOM 209	2ND DRAW		
520-33	STAFF BATH 2ND FLR	1ST DRAW		

3192  
 905138

APR 20 2023

52 <sup>AA</sup> II	STAFF BATH 2ND FLR	2ND DRAW		
520-35	ROOM 207	1ST DRAW		
520-36	ROOM 207	2ND DRAW		
520-37	GIRLS BATH BSMNT	SINK 1 1ST DRAW		
520-38	GIRLS BATH BSMNT	SINK 1 2ND DRAW		
520-39	GIRLS BATH BSMNT	SINK 2 1ST DRAW		
520-40	GIRLS BATH BSMNT	SINK 2 2ND DRAW		
520-41	GIRLS BATH BSMNT	SINK 3 1ST DRAW		
520-42	GIRLS BATH BSMNT	SINK 3 2ST DRAW		
520-43	GIRLS BATH BSMNT	SINK 4 1ST DRAW		
520-44	GIRLS BATH BSMNT	SINK 4 2ND DRAW		
520-45	BOYS BATH BSMNT	SINK 1 1ST DRAW		
520-46	BOYS BATH BSMNT	SINK 1 2ND DRAW		
520-47	BOYS BATH BSMNT	SINK 2 1ST DRAW		
520-48	BOYS BATH BSMNT	SINK 2 2ND DRAW		
520-49	BOYS BATH BSMNT	SINK 3 1ST DRAW		
520-50	BOYS BATH BSMNT	SINK 3 2ST DRAW		

TAKEN AND RELINQUISHED BY ARIEL KINSBURSKY

DATE: 4/17/2023

A. kinsbursky

APR 20 2023