



6 White Dove Ct. Lakewood NJ 08701  
Tel- (732)668-9078 Fax – (732)358-0168  
Cert # 00407A Cert # 00430E  
Asb # 01200

---

04/25/2023

Re: 544 CHESTNUT AVE TRENTON NJ 08611

To whom it may concern,

We have sampled the drinking water at the above property for copper and lead . Please note the Federal Action for copper is 1,300 ug/l (ppb) and lead is 15 ug/l (ppb).

The following lead results were found to be above the action level:

- RM 201 1ST DRAW

All copper results were found to be below the action level.

Feel Free to contact us with any questions.

*A. Kinsbursky*

Ariel Kinsbursky  
732-668-9078



30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-629-8161; Fax: 734-629-8431

## Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

**Client :** AAA Lead Professionals  
 6 White Dove Court  
 Lakewood, NJ 08701

**Attn :** Joseph Perlstein      **Email :** joe@aaaleadpro.com  
**Phone :** 732-668-9078      **Fax :**

**AAT Project :** 905136  
**Sampling Date :** 04/17/2023  
**Date Received :** 04/20/2023  
**Date Analyzed :** 04/21/2023  
**Date Reported :** 04/25/2023

**Client Project :** 544 CHESTNUT AVE TRENTON      **Collected By :** ARIEL KINSBURSKY

**WSSN :**

**Project Location :** 544 CHESTNUT AVE TRENTON NJ

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
8363673	544-1	BOYS BATH 3RD FLR 1ST DRAW	NA	0	0.0020	0.0020	Below
8363674	544-2	BOYS BATH 3RD FLR 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363675	544-3	RM 305 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363676	544-4	RM 305 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363677	544-5	GIRLS BATH 3RD FLR 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363678	544-6	GIRLS BATH 3RD FLR 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363679	544-7	GIRLS BATH 2ND FLR 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363680	544-8	GIRLS BATH 2ND FLR 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363681	544-9	BOYS BATH 2ND FLR 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363682	544-10	BOYS BATH 2ND FLR 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363683	544-11	RM 201 1ST DRAW	NA	0	0.05379	0.0020	Above
8363684	544-12	RM 201 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363685	544-13	RM 202 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363686	544-14	RM 202 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363687	544-15	BOYS BATH 1ST FLR 1ST DRAW	NA	0	0.0025	0.0020	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu  
 The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 04/25/2023

AAT Project: 905136

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead mg/L (ppm)	Reporting Limit	Pb Threshold
8363688	544-16	BOYS BATH 1ST FLR 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363689	544-17	GIRLS BATH 1ST FLR 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363690	544-18	GIRLS BATH 1ST FLR 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363691	544-19	STAFF WORK RM SINK 1 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363692	544-20	STAFF WORK RM SINK 1 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363693	544-21	STAFF WORK RM SINK 2 1ST DRAW	NA	0	0.0024	0.0020	Below
8363694	544-22	STAFF WORK RM SINK 2 2ND DRAW	NA	0	<0.0020	0.0020	Below
8363695	544-23	STAFF BATH RM 1ST FLR 1ST DRAW	NA	0	<0.0020	0.0020	Below
8363696	544-24	STAFF BATH RM 1ST FLR 2ND DRAW	NA	0	<0.0020	0.0020	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-629-8161; Fax: 734-629-8431

## Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

**Client :** AAA Lead Professionals  
 6 White Dove Court  
 Lakewood, NJ 08701

**Attn :** Joseph Perlstein      **Email :** joe@aaaleadpro.com  
**Phone :** 732-668-9078      **Fax :**

**AAT Project :** 905136  
**Sampling Date :** 04/17/2023  
**Date Received :** 04/20/2023  
**Date Analyzed :** 04/21/2023  
**Date Reported :** 04/25/2023

**Client Project :** 544 CHESTNUT AVE TRENTON N    **Collected By :** ARIEL KINSBURSKY  
**Project Location :** 544 CHESTNUT AVE TRENTON NJ

**WSSN :**

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
8363673	544-1	OYS BATH 3RD FLR 1ST DRAI	NA	0	0.0400	Below
8363674	544-2	OYS BATH 3RD FLR 2ND DRAI	NA	0	0.0183	Below
8363675	544-3	RM 305 1ST DRAW	NA	0	0.0276	Below
8363676	544-4	RM 305 2ND DRAW	NA	0	<0.0025	Below
8363677	544-5	IRLS BATH 3RD FLR 1ST DRAI	NA	0	0.0378	Below
8363678	544-6	IRLS BATH 3RD FLR 2ND DRA	NA	0	0.0229	Below
8363679	544-7	IRLS BATH 2ND FLR 1ST DRAI	NA	0	0.0289	Below
8363680	544-8	IRLS BATH 2ND FLR 2ND DRA	NA	0	0.0230	Below
8363681	544-9	OYS BATH 2ND FLR 1ST DRAI	NA	0	0.0188	Below
8363682	544-10	OYS BATH 2ND FLR 2ND DRAI	NA	0	0.0182	Below
8363683	544-11	RM 201 1ST DRAW	NA	0	0.1455	Below
8363684	544-12	RM 201 2ND DRAW	NA	0	0.0284	Below
8363685	544-13	RM 202 1ST DRAW	NA	0	0.1245	Below
8363686	544-14	RM 202 2ND DRAW	NA	0	0.0359	Below
8363687	544-15	OYS BATH 1ST FLR 1ST DRAI	NA	0	0.0510	Below
8363688	544-16	OYS BATH 1ST FLR 2ND DRAI	NA	0	0.0194	Below
8363689	544-17	IRLS BATH 1ST FLR 1ST DRAI	NA	0	0.0251	Below
8363690	544-18	IRLS BATH 1ST FLR 2ND DRAI	NA	0	0.0189	Below
8363691	544-19	\FF WORK RM SINK 1 1ST DR	NA	0	0.0376	Below
8363692	544-20	\FF WORK RM SINK 1 2ND DR	NA	0	0.0255	Below

ND = Not Detected, N/A = Not Available, RL = Reporting Limit. The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results

relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted.

All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 04/25/2023

AAT Project: 905136

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper mg/L (ppm)	Cu Threshold
8363693	544-21	\FF WORK RM SINK 2 1ST DR	NA	0	0.1173	Below
8363694	544-22	\FF WORK RM SINK 2 2ND DR	NA	0	0.0314	Below
8363695	544-23	\FF BATH RM 1ST FLR 1ST DR	NA	0	0.0827	Below
8363696	544-24	\FF BATH RM 1ST FLR 2ND DF	NA	0	0.0401	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 0.002 mg/L (ppm) and for Cu is 0.0025 mg/L (ppm).

For true values assume (2) significant figures. AAT internal SOP S230. The method and batch QC are acceptable unless otherwise stated.

EPA Regulatory Limits: 0.015 mg/L for Pb and 1.3 mg/L for Cu

The laboratory operates in accord with NELAC guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results

relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted.

All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.





30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-629-8161; Fax: 734-629-8431

To : AAA Lead Professionals  
 6 White Dove Court  
 Lakewood, NJ 08701

AAT Project : 905136  
 Client Project : 544 CHESTNUT AVE TRENTON  
 Date Reported : 04/25/2023

Attn : Joseph Perlstein      Email : joe@aaaleadpro.com  
 Phone : 732-668-9078

Project Location : 544 CHESTNUT AVE TRENTON NJ

Sample	Client Code	Analysis Requested	Completed	Analyst
8363673	544-1	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363674	544-2	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363675	544-3	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363676	544-4	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363677	544-5	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363678	544-6	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363679	544-7	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363680	544-8	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363681	544-9	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363682	544-10	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363683	544-11	Pb/Cu in Drinking Water	04/24/2023	Joseph Kenwabikise
8363684	544-12	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363685	544-13	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363686	544-14	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363687	544-15	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363688	544-16	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363689	544-17	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363690	544-18	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363691	544-19	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363692	544-20	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363693	544-21	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363694	544-22	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363695	544-23	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise
8363696	544-24	Pb/Cu in Drinking Water	04/21/2023	Joseph Kenwabikise

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.



Reviewed By

Elyse Bidle  
Quality Assurance Coordinator

---

This report is intended for use solely by the individual or entity to which it is addressed. It may contain information that is privileged, confidential and otherwise exempt by law from disclosure. If the reader of this information is not the intended recipient or an employee of its intended recipient, you are herewith notified that any dissemination, distribution or copying of this information is strictly prohibited. If you have received this information in error, please notify AAT immediately. Thank you.

AAA LEAD PROFESSIONALS  
6 WHITE DOVE CT  
LAKEWOOD NJ 08701  
732-668-9078

72 HR

CHAIN OF CUSTODY

544 CHESTNUT AVE TRENTON NJ

8763673

Lead & Copper

SAMPLE	ROOM	PLACE	AREA	
544-1	BOYS BATH 3RD FLR	1ST DRAW		
544-2	BOYS BATH 3RD FLR	2ND DRAW		
544-3	ROOM 305	1ST DRAW		
544-4	ROOM 305	2ND DRAW		
544-5	GIRLS BATH 3RD FLR	1ST DRAW		
544-6	GIRLS BATH 3RD FLR	2ND DRAW		
544-7	GIRLS BATH 2ND FLR	1ST DRAW		
544-8	GIRLS BATH 2ND FLR	2ND DRAW		
544-9	BOYS BATH 2ND FLR	1ST DRAW		
544-10	BOYS BATH 2ND FLR	2ND DRAW		
544-11	ROOM 201	1ST DRAW		
544-12	ROOM 201	2ND DRAW		
544-13	ROOM 202	1ST DRAW		
544-14	ROOM 202	2ND DRAW		
544-15	BOYS BATH 1ST FLR	1ST DRAW		
544-16	BOYS BATH 1ST FLR	2ND DRAW		
544-17	GIRLS BATH 1ST FLR	1ST DRAW		
544-18	GIRLS BATH 1ST FLR	2ND DRAW		
544-19	STAFF WORK ROOM	SINK 1 1ST DRAW		
544-20	STAFF WORK ROOM	SINK 1 2ND DRAW		
544-21	STAFF WORK ROOM	SINK 2 1ST DRAW		
544-22	STAFF WORK ROOM	SINK 2 2ND DRAW		
544-23	STAFF BATH RM 1ST FLR	1ST DRAW		
544-24	STAFF BATH RM 1ST FLR	2ND DRAW		

TAKEN AND RELINQUISHED BY ARIEL KINSBURSKY

DATE: 4/17/2023

A. Kinsbursky

APR 20 2023

3192  
905136